

AMENDMENT TO RENEWABLE ENERGY APPROVALNUMBER 6662-8QVM6U
Issue Date: June 19, 2014

Northland Power Solar Burk's Falls East GP Inc.
30 St. Clair Avenue West, 17 th Floor
Toronto, Ontario
M4V 3A1

Site Location: 827 Chetwynd Road
Township of Armour, District of Parry Sound
P0A 1C0

You are hereby notified that I have amended Approval No. 6662-8QVM6U issued on February 14, 2012 for a Class 3 solar project , as follows:

- A. The definitions of "Acoustic Assessment Report" and "Application" in the Approval are deleted and replaced by the following:**
1. "Acoustic Assessment Report" means the report included in the Application and entitled "Burk's Falls East Solar Project Noise Assessment Assessment Study Report", prepared by HATCH, dated August 15, 2011 and updated December 11, 2013;
 7. "Application" means the application for a Renewable Energy Approval dated June 8, 2011, and signed by Sam Mantenuto, Chief Operating Officer, Northland Power Solar Burk's Falls East GP Inc., on behalf of Northland Power Solar Burk's Falls East L.P., and all supporting documentation submitted with the application, including amended documentation submitted up to January 31, 2012, and as further amended by the application for a Renewable Energy Approval dated February 20, 2013 to amend the Renewable Energy Approval number 6662-8QVM6U, and signed by Jim Mulvale, Manager, EH&S, Northland Power Solar Burk's Falls East GP Inc., and all supporting documentation submitted with the application, including amended documentation submitted up to March 1, 2013, and as further amended by the application for a Renewable Energy Approval dated December 12, 2013 to amend the Renewable Energy Approval number 6662-8QVM6U, and signed by Jim Mulvale, Manager, EH&S, Northland Power Solar Burk's Falls East GP Inc., and all supporting documentation submitted with the application, including amended documentation submitted up to April 29, 2014.
- B. The Schedule A in the Approval is deleted and replaced by the following:**

SCHEDULE A

Coordinates of the Equipment and Noise Specifications

Coordinates of the Equipment are listed below in UTM, Z17-NAD83 projection:

Source ID	Sound Power Level (dBA)	Easting (m)	Northing (m)	Source Description
Inv1	91.3	627981	5051831	Inverters at Cluster 1
Inv2	91.3	628039	5051991	Inverters at Cluster 2
Inv3	91.3	628180	5052156	Inverters at Cluster 3
Inv4	91.3	628528	5051945	Inverters at Cluster 4
Inv5	91.3	628446	5052085	Inverters at Cluster 5
Inv6	91.3	628404	5052195	Inverters at Cluster 6
Inv7	91.3	628376	5052309	Inverters at Cluster 7
Trans1	80.1	627986	5051831	Transformer at Cluster 1
Trans2	80.1	628044	5051990	Transformer at Cluster 2
Trans3	80.1	628186	5052155	Transformer at Cluster 3
Trans4	80.1	628533	5051945	Transformer at Cluster 4
Trans5	80.1	628451	5052085	Transformer at Cluster 5
Trans6	80.1	628409	5052195	Transformer at Cluster 6
Trans7	80.1	628381	5052309	Transformer at Cluster 7
Sub	90.8	628088	5052242	Transformer Substation

Note: The inverter and transformer Sound Power Level values in the above table correspond to the combined output of all the inverters in each cluster, and include the 5 Decibel (dB) adjustment for tonality as prescribed in Publication NPC-104.

All other Terms and Conditions of the Approval remain the same.

This Notice shall constitute part of the approval issued under Approval No. 6662-8QVM6U dated February 14, 2012

In accordance with Section 139 of the Environmental Protection Act, within 15 days after the service of this notice, you may by further written notice served upon the Director, the Environmental Review Tribunal and the Environmental Commissioner, require a hearing by the Tribunal.

In accordance with Section 47 of the Environmental Bill of Rights, 1993, the Environmental Commissioner will place notice of your request for a hearing on the Environmental Registry.

Section 142 of the Environmental Protection Act provides that the notice requiring the hearing shall state:

1. The portions of the renewable energy approval or each term or condition in the renewable energy approval in respect of which the hearing is required, and;
2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The signed and dated notice requiring the hearing should also include:

3. The name of the appellant;
4. The address of the appellant;
5. The renewable energy approval number;
6. The date of the renewable energy approval;
7. The name of the Director;
8. The municipality or municipalities within which the project is to be engaged in;

This notice must be served upon:

The Secretary*
Environmental Review Tribunal
655 Bay Street, 15th Floor
Toronto, Ontario
M5G 1E5

AND

The Environmental Commissioner
1075 Bay Street, 6th Floor
Suite 605
Toronto, Ontario
M5S 2B1

AND

The Director
Section 47.5, *Environmental Protection Act*
Ministry of the Environment
2 St. Clair Avenue West, Floor 12A
Toronto, Ontario
M4V 1L5

*** Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 314-4600, Fax: (416) 314-4506 or www.ert.gov.on.ca**

Under Section 142.1 of the Environmental Protection Act, residents of Ontario may require a hearing by the Environmental Review Tribunal within 15 days after the day on which notice of this decision is published in the Environmental Registry. By accessing the Environmental Registry at www.ebr.gov.on.ca, you can determine when this period ends.

Approval for the above noted renewable energy project is issued to you under Section 47.5 of the Environmental Protection Act subject to the terms and conditions outlined above.

DATED AT TORONTO this 19th day of June, 2014



Ian Parrott, P.Eng.
Director
Section 47.5, *Environmental Protection Act*

YB/

- c: Area Manager, MOE North Bay
- c: District Manager, MOE Sudbury
- Sean Male, Hatch

